

SECTION 100

PORTLAND CEMENT

100.1 DESCRIPTION

A. General

Portland cement shall be used as called for herein.

B. Related Work

Section 40 Portland Cement Concrete Pavement
Section 55 Concrete Masonry
Section 56 Concrete for Incidental Construction (Class M)
Section 60 Concrete Curb And Gutter
Section 61 Concrete Sidewalk And Handicap Ramps
Section 62 Drop Inlets
Section 67 Fabric Formed Concrete Mat

100.2 MATERIALS (Not specified)

100.3 CONSTRUCTION REQUIREMENTS

Portland Cement shall conform to the requirements of AASHTO M 85 for the type specified. Type II cement shall not have more than 0.60 percent of Alkalies ($\text{Na}_2\text{O} + 0.658\text{K}_2\text{O}$).

Unless otherwise permitted by the Engineer, the product of only one mill of any one brand and type of Portland cement shall be used on the project.

100.4 METHOD OF MEASUREMENT & 100.5 BASIS OF PAYMENT

Portland cement shall be incidental to and shall be paid as a part of the individual bid item. There will be no separate measurement and payment for Portland cement.

END OF SECTION