

Quality Transportation, Inc.

P.O. BOX 1530

BAKER, MT 59313

ICC - MC - 185031

US DOT 265176

TELEPHONE (408) 778-3304

TOLL FREE (800) 423-0141

FAX (406) 778-3196

www.quality-transportation.com

September 17, 2018

Brad Solon

Rapid City Planning and Zoning:

During our final building inspection it was brought to our attention that the microhood in our kitchen area that is not vented to the outside is not to code/ordinance. While we are a commercial building, we are not using commercial appliances nor will we be using the range and microhood on a daily basis.

We are requesting an exception the city code/ordinance as it is defined as we feel that it does not apply to our business since we are using this as a residential application and the microhood can be set to recirculate. Also, we do have a fire suppression system in place in our building.

We appreciate your time and consideration to this matter. Please let us know what steps are needed to proceed with getting our request approved.

Thanks so much,



Kammi Doud

Safety Supervisor

Quality Transportation, Inc.

605-341-1296 or 605-381-8530

Kammid@quality-transportation.com

**NOTICE OF APPEAL AND HEARING THEREON
BEFORE THE BUILDING BOARD OF APPEALS**

NOTICE IS HEREBY GIVEN THAT the following have appealed to the **Building Board of Appeals**.

Kammi Doud appeals the decision of the Building Official to the RCMC 15.26.220 IMC Section 507.21 Hoods. Doud's appeals to allow a residential re-circulating hood, in lieu of the required Type I or II for sprinkled buildings.

BE IT FURTHER GIVEN THAT SAID appeal will be heard by the **Building Board of Appeals** at the City School Administration Building, 300 Sixth Street, at **7:30 a.m. on Tuesday, October 9, 2018** at which time and place any person interested may attend.

Dated at Rapid City, South Dakota
September 26, 2018

(Publish on Saturday September 29, 2018)