

**REQUEST FOR EXCEPTION TO
RAPID CITY DESIGN STANDARD / CRITERIA / REGULATIONS**

PROJECT BOB AND GLENDA WILLIAMS

DATE: 12/18/23

SUBMITTED BY:
(Include Name, Company Name,
Email Address & Phone Number)

JASON PHILLIPS
TERRASITE DESIGN (605) 416-2024
JASON.PHILLIPS@TERRASITEDESIGN.COM

PIN #: _____

LEGAL DESCRIPTION: 2627 SKYLINE DRIVE RAPID CITY, SD 57701
LOT 1 BLOCK 1 SECTION 11 TOWNSHIP 1N RANGE 07E

EXCEPTION REQUESTED: SECTION 2.12.2 STD / CRITERIA / REG CRITERIA

DESCRIPTION OF REQUEST: _____

The request for an exception has been made to leave the existing boulder walls, existing cut-bank/berm, and add additional boulders in the right-of-way.

JUSTIFICATION:

(Please use back of sheet if additional room is needed)

See attached justification narrative.

SUPPORTING DOCUMENTATION: Yes No

PROPERTY OWNER'S SIGNATURE**: [Signature] DATE: 12.18.2023

**Or Agent, if previously designated by the Owner in writing.

FOR STAFF ONLY

STAFF COMMENTS: No objects are allowed in the right-of-way.

SIGHT TRIANGLE MUST BE MAINTAINED
IAW STATE 10CM.

STAFF RECOMMENDATION: Deny

REVIEWED BY: Engineering Division

DATE: 1/9/24

AUTHORIZATION:

APPROVED

DENIED

COMMUNITY PLANNING DIRECTOR

[Signature]

APPROVED

DATE DENIED

1/9/24
DATE

PUBLIC WORKS DIRECTOR

FILE #: 23EX104

Revised 07/1/14

ASSOCIATED FILE#: _____

RECEIVED

Copy to Utility Maintenance: _____ Copy to Water: _____ Copy to Waste Water: _____ Copy to Streets: _____ Copy to Traffic: _____ Copy to Construction: DEC 18 2023

ENGINEERING SERVICES